



TVA Operations

Operating Experience Communication

Power Portable Gasoline Generators Recalled - 09/14/2016

Purpose

This OE communication is being shared to ensure recalled Power Portable Generators by J.D. North America are removed from service.

Background

J.D. North America is issuing a recall of all Power Portable Gasoline Generators due to fuel tanks leaking, which can cause explosion, fire and burn hazards.

Findings

- J.D. North America has received 21 reports of fuel leakage. No injuries or property damage have been reported.

REQUIRED ACTIONS

- Each site is to review this OE for awareness and site application.
- Users identifying equipment affected by this recall must inform their supervisors immediately and tag the equipment defective.
- Identify all generators affected by this recall and remove from service immediately. Tag generators to ensure they are not returned to service. Affected model numbers are listed below.
- Contact J.D. North America to schedule a free fuel tank replacement, including installation.

Affected Model Numbers

Model Number	Rated	UPC	Serial Number
APGG6000	6,000 watts	8 4676600055 3	JD29014S18035
APGG7500	7,500 watts	8 4676600056 0	JD42014S16027 - JD42014T210606

- The model number is located on both sides of the unit.
- The UPC code and serial number can be found on a silver plate on the upper right hand-side of the back side panel.
- Contact J.D. North America toll-free at (844) 287-4655 from 9 a.m. to 5 p.m. ET Monday through Friday by email at apggrecall@jdna.com, or online at www.allpoweramerica.com and click on the APGG Recall link for more information.

